

ANNEXURE-C

PROFORMA FOR DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO - 97

Dated:

It is certified that an inspection team headed by

Aswish Kapse (C.S.I.) (Name of Officer with designation)

From ----- PHED

Inspected the New Era Public Academy

On 08/07/26 and on the basis of Water Test Report being no. U/GF-026070300003

Dated 08/07/26 of RAM 2 LABORATORIES PVT. LTD. (PHED Lab)

Certified that the

New Era Public Academy has safe drinking water

Facilities for the students and members of staff of the institution. School is also maintains the hygienic condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 2026 - 2027

Signature with Seal

Name:

Designation:

Name & Address of the Office/Department

To

Chief Sanitary Inspector
Nager Palika, Nijam Indore,
Mahatma Gandhi Zone - 17
Saver Road Indore.
7440443437

TEST REPORT

Report Number	U/GE-026070300003	Report Date	08/07/2026
Sample Name	RO Water		
Sender/Party Name	New Era Public Academy , Opp Idea Tower , Near Nirwana Resort, MR10,Indore .		
Batch /Code No.	NA	Sample Quantity	1 Liter
Mfg. in	NA	Batch Size	NA
Exp. in	NA	Condition of sample	Ok
Sample Receipt Date	03/07/2026	Customer Reference	NA
Analysis Start Date	03/06/2026	Analysis Completion Date	08/07/2026

Sr. No.	Test Parameter	Specification Limits & Standard Reference (IS:10500:2012)	Method of Analysis	Test Results	Units
1	Colour	Max. 5	IS 3025 Part-4	1	Hazen
2	Odour	Agreeable	IS 3025 Part-5	Agreeable	--
3	Taste	Agreeable	IS 3025 Part-7	Agreeable	--
4	Turbidity	Max. 1	IS 3025 Part-10	0.32	NTU
5	pH	6.5 – 8.5	IS 3025 Part-11	8.17	--
6	Total Hardness	Max. 200	IS 3025 Part-21	33.0	mg/L
7	Calcium	Max. 75	IS 3025 Part-40	25.22	mg/L
8	Chlorides (Cl)	Max. 250	IS 3025 Part-32	24.97	mg/L
9	Total Alkalinity	Max. 200	IS 3025 Part-23	37.85	mg/L
10	Total Dissolved Solid	Max. 500	IS 3025 Part-16	211	mg/L
11	Sulphate (SO ₄)	Max. 200	IS 3025 Part-29	0.59	mg/L

TEST REPORT

Report Number	U/GE-026070300003	Report Date :08/07/2026
----------------------	-------------------	--------------------------------

Sr. No.	Test Parameter	Specification Limits & Standard Reference (IS:10500:2012)	Method of Analysis	Test Results	Units
12	Nitrite	Max 45	IS 3025 Part-34	0.1	mg/L
13	Flouride (ASF)	Max 1	IS 3025 Part-60	0.8	mg/L
14	Phenolic Compounds	Max 0.001	IS 3025 Part-43	ND	-
15	Magnesium	Max 30	IS 3025 Part-46	1.1	mg/L
16	Residual Free Chlorine	Max 0.2	IS 3025 Part-26	ND	mg/L

Remark: Sample complies as per IS 10500:2012 specification with respect to above test only.

 Checked By	 Authorized Signatory
--	--

****End of Report****